


# 6'-0" X 12'-0"

38Y NSS MANHOLE



Two-Piece Manhole				
HEADROOM		ROOF	WALL	FLOOR
TOP	BASE			
3'-9"	3'-3"	6"	5 1/2"	6"

**AC MILLER**  
CONCRETE PRODUCTS, INC.  
WWW.ACMILLER.COM



31 E. BRIDGE ST.  
P.O. BOX 199  
SPRING CITY  
PA. 19475  
9558 ROUTE 22  
P.O. BOX 93  
BLAIRSVILLE,  
PA. 15717

PHONE:  
(610) 948-4600  
FAX:  
(610) 948-9750  
PHONE:  
(724) 459-5950  
FAX:  
(724) 459-9151

Precast Concrete Utility Vaults  
6'-0" X 12'-0"  
38Y NSS Manhole


FILE NAME: 06x12 38Y P1

DATE: 9/5/05


DRAWN BY: BTH

This manhole come equipped with  
1 or 2 access holes per job requirements.

**6'-0" X 12'-0"**  
38Y NSS MANHOLE



PLAN VIEW



SECTION VIEW

\* PLEASE NOTE:  
ACM USES INSIDE DIMENSIONS TO  
DESCRIBE VAULT SIZE.

\* FOR ANY ADDITIONAL  
INFORMATION PLEASE CONTACT  
A.C. MILLER SALES  
REPRESENTATIVE

JOB: \_\_\_\_\_  
CUSTOMER: \_\_\_\_\_  
DRAWING \_\_\_ OF \_\_\_

LIVE LOAD: HS-20  
EARTH COVER: 0 to 2 ft.  
CONCRETE: 5000 psi AT 28 DAYS  
REBAR: GRADE 60, ASTM A615 SPEC'S  
PRECAST CONCRETE VAULT CONFORMS TO ASTM C890  
AND C913 SPECIFICATIONS



31 E. BRIDGE ST.  
P.O. BOX 199  
SPRING CITY  
PA. 19475  
PHONE: (610) 948-4600  
FAX: (610) 948-9750  
9558 ROUTE 22  
P.O. BOX 93  
BLAIRSVILLE,  
PA. 15717  
PHONE: (724) 459-5950  
FAX: (724) 459-9151

**Precast Concrete Utility Vaults**  
**6'-0" X 12'-0"**  
**38Y NSS Manhole**

FILE NAME: 06x12 38Y P2

DATE: 9/5/05

DRAWN BY: BTH